



DEEP EDUCATION SOCIETY'S
Deep Global School CBSE

Affiliation No. : 1130974

Deep Campus Boisar, Opp. G. R. Engineering, Saravali,
Boisar (W), Tal. & Dist. Palghar, Pin - 401 501. Ph. : 7066080003 / 7030996452

DGS/2025-26/No.23

Date: 25/04/2025

To,

Mr. Dilip Madhav Palav
Chief Fire Officer
Vasai Virar City Municipal Corporation

Subject: Application for Fire Safety Certificate

Dear Sir,

With reference to the subject mentioned above, we are submitting the necessary documents for the Fire Safety Certificate.


We kindly request you to accept our application and process the same at the earliest possible convenience. Your assistance in this matter will be greatly appreciated.

Thank you for your support and cooperation.

PRINCIPAL

DEEP GLOBAL SCHOOL
NEXT TO SAIDHAM COMPLEX,
SARAVALI, BOISAR (WEST), TAL. PALGHAR,
DIST - PALGHAR, PIN-401 501.

DEEP EDUCATION SOCIETY

Chairman



NEW SERVICES

The Alarm System

REF: NAFS/F-B /25-26/11/07/105

Date: 11/07/2025

FORM B

[See section 3(3) and rule 4(2)]

Six monthly Certificate to be given in every January and June by the occupier for compliance of the Fire prevention and life safety measures.

CERTIFICATE

Certified that I/we have carried out inspection of the Fire prevention and life safety measures installed in the following building or premises, namely :-

M/s. Deep Education Society

S. No. 39/1/2, (Old S.

No. 151/1),

At sarawali, Tal & Dist-
Palghar.

I/we further certify that these installations in the above mentioned building are maintained in good repair and efficient conditions during the period January 2025 to June 2025 as required under the provision of the Maharashtra Fire Prevention And Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection of installation carried out by me/us are mentioned in the report appended herewith.

Details of inspection and maintenance/servicing are as per attached list.

Place : Boisar

Authorized Signature

Address of Licensed Agency : L-3 Sundaram Apartment,
Ostwal Empire Boisar 401506.

License no: - MFS/LA/RF-73

License no: - MFS/LA/D - 499

DEEP EDUCATION SOCIETY

Chairman

PRINCIPAL
DEEP GLOBAL SCHOOL
NEXT TO SPANNA COMPLEX,
SARAWALI, BOISAR (WEST), TAL. PALGHAR,
DIST - PALGHAR, PIN-401 501.



7764114418 / 9423371278 Office :- Bldg No 1-3, Sundar
Boisar 401500
newaimfireservice2010@gmail.com Ostwal Empire, Boisar 401500

AIM NEW SERVICES

ANNEXURE

REF: NAFS/F-B /25-26/11/07/105

Date: 11/07/2025

M/s. Deep Education Society
S. No. 39/1/2, (Old S. No. 151/1),
At sarawali, Tal & Dist-Palghar.

Annexure to Form B

1. System Statement for the Fire Extinguishers, Fire Alarm System & Fire Hydrant System.

Sr. No.	Description	Qty
A.	Hydrant Systems	
01.	Hydrant Main Pump (7.5 HP)	02 Nos.
02.	Hydrant Jockey Pump (7.5 HP)	01 Nos.
03.	Booster Pump (5.5 HP)	01 Nos.
04.	Hydrant Valve	01 Nos.
05.	Single Door Hose Box	09 Nos.
06.	Hose Pipe	09 Nos.
07.	Branch Pipe	09 Nos.
08.	Hose Reel Drum with Hose Pipe.	05 Nos.
09.	Fire Brigade Connection 4 Way.	01 Nos.
B.	Fire Alarm System	
01.	Fire Alarm Panel 04 Zone	01 Nos.
02.	Manual Call Point	09 Nos.
03.	Hooter	06 Nos.
C.	Fire Extinguishers	

Signature

Signature

01.	ABC Stored Pressure Powder Type Fire Extinguishers Capacity 6 Kg.	04 Nos.
02.	CO2 Type Fire Extinguishers Capacity 3.2 Kg	01 Nos.

Authorized Signature



Contact No. 02525-267454 Work :- Street - I, Awadh Nagar, Navapur,
Boisar 401506, Dist. Palghar
Contact No. 9823162689 / 7875293195
9764114418 / 9423371278 Office :- Bldg No L-3, Sundarab
newaimfireservice2010@gmail.com Ostwal Empire, Boisar 401506, Dist.

DEEP EDUCATION SOCIETY


Chairman



PRINCIPAL
DEEP GLOBAL SCHOOL
NEXT TO SANGHOM COMPLEX,
SARAVALI, BLDG NO. 1, WEST, TAL. PALGHAR,
DIST - PALGHAR, PIN-401 501.

मुख्य कार्यालय, विरार

विरार (पूर्व)

बसई, जि.पालघर-४०१ ३०५.



दूरध्वनी: ०२१०-२५२५३०१/०२/०३/०४/०५/०६

फॅक्स : ०२१०-२५२५३०५

ई-मेल: fire,vvcmc@gov.in

जा.क्र. :MFS/VVCMC/FIRE/HQ/04/2024-25

दिनांक:25/04/2024

FIRE SAFETY CERTIFICATE

Certified that the Deep Global School, Boisar (W) of Deep Education Society's. At Opp G.R. Engineering Company, MIDC, Next to Saidham Complex, Saravali, Boisar (W), Tal & Dist-Palghar - 401 501. Comprised of Ground Floor + 3 upper Terrace Floor occupied by Deep Global School, Boisar (W) under Deep Education Society's have complied with the fire prevention and fire safety requirements in accordance with rule of State fire service Rules, and verified by the officers concerned of Fire service on **25/04/2024** in the presence of **Mrs.Vrinda Sachin Kulkarni, Principal of Deep Global School, Boisar (W)** and that the building / premises is Fit for occupancy upto Classes - I to X with effect from valid for the period of **1 (One) Year** from the date of issue. In accordance with rule and subject to compliance of the condition.

M/s- Deep Global School, Boisar (W) has paid Fire & Emergency Service Fees of Rs.1300/- (Rs. One Thousand Three Hundred Only) in reference to Transaction No.1487127208, Dated:04/03/2024.

PRINCIPAL

DEEP GLOBAL SCHOOL
NEXT TO SAIDHAM COMPLEX,
SARAVALI, BOISAR (WEST), TAL. PALGHAR,
DIST - PALGHAR, PIN-401 501.

Dilip

Mahadev

Palav

Digitally signed by

Dilip Mahadev

Palav

Date: 2024.04.25

14:23:27+05'30'

Dilip M.Palav

Chief Fire Officer

Vasai Virar City Municipal Corporation